

## Annexure-B



### CERTIFICATE OF LAND

Date: 14-10-24

Certified that land measuring 2 Acres 4 Guntas/8255.587sq. meters) own by **RR Educational and Charitable Trust** KGF represented by its Secretary **AHMED SHARIEF** by way of gift deed.

SL No	Particulars	Details
01	Plot No/Survey No/Khasra No/Khata No	S.No 45/1, 45/2,45/3 and Khata No-56
02	Name of the Village, Sub Division, District & State	Surahalli Villiage, Robertsobnpet Hubli, KGF Tk, Kolar District, Karnataka

It is certified that the entire land comprise of a single contiguous plot of land. It is certified that RR International School opp Pandarlane, Marikuppam Post-563119, Surahalli Village KGF Tk, Kolar District. Run by the name of RR Educational and Charitable Trust ® KGF-563119.

### THE SCHEDULE OF LAND ABOVE REFERRED TO

All that piece and parcel of land measuring 2 Acres 4 Guntas / 8255.587 sq. meters) situated in Survey No-45/1, 45/2, 45/3 of Surahalli Village Robertsonpet Hobli KGF-563119 Tk, Kolar District and Karnataka state and total Land is bounded as follows ,

North By : Surahalli Road  
East By : S.No-46/1 own Land  
West By : BM Road  
South By: S.No-41

  
**TAHSILDHAR**  
**BANGARPET TALUK**



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಪೀಠಿಕೋಪಯೋಗಿ ಇಲಾಖೆ

ಸಾರ್ವಜನಿಕ ಕಾರ್ಯದರ್ಶಿಗಳ ಕಛೇರಿ, ಪೀಠಿಕೋಪಯೋಗಿ ಇಲಾಖೆ, ೨ನೇ ಹಂತ, ಕೆ.ಆರ್.ನಗರ  
ಬೆಂಗಳೂರು-೫೬೩೧೦೧ e-mail: aeeepwdkgf@gmail.com

Annexure D

## BUILDING SAFETY CERTIFICATE

No-AEE/PWD/SD/115/2025-26

Dated: 08.04.2025

It is certified that the existing building RR International School at BM Road Opp Pandarlane Marikuppam Post KGF-563119. (Address) is having Block(s)/Floor(s) as per details below.

Detail of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)
No of Floor(s) in the Block	Ground + 3 Floors				

The building is owned/occupied by RR Educational & Charitable Trust have complied with the building safety requirements in accordance with National Building code Rules, and verified by the officer concerned of Asst Executive Engineer PWD KGF on 05.04.2025 (dated of Inspection) in the presence of Sir. Ahmed Sharief Secretary RR Educational & Charitable Trust and that the building/premises is fit for occupancy for running school with effect from 01-04-2025 for a period of 5 years (31-03-2030) in accordance with rule and subject compliance of the specific conditions as appended .

1. Lift is provided for Physical Handicapped Students.
2. Stair Case with is 1.5 Mts and Rise of step is 0.15 Mts
3. Ceiling height from flour measure and it is 3.15 Mts
4. Paved Road available for the movement of fire engine around the building.

Issued on 08.04.2025 at KGF

Signature with Seal  
Name  
Designation

*SRINIVAS*  
Asst Executive Engineer  
PWD (SUBD) Robertsonpet  
KGF - 563122.



ನಗರಸಭಾ ಕಾರ್ಯಾಲಯ

ರಾಬರ್ಟ್ಸನ್‌ಪೆಟ್, ಕೆ.ಜಿ.ಎಫ್. - 563 122.

**CITY MUNICIPAL COUNCIL**  
ROBERTSONPET, K.G.F - 563 122.

STD : 01853  
☎ : 260256

**ANNEXTURE-C**

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No.CMC/KGF/141/2025

Dated: 05/04/2025

It is certified that an inspection team headed by M SRIDHRAN Asst Executive Engineer CMC Robertsobnpet, KGF inspected the RR INTERNATIONAL SCHOOL BM ROAD, OPP PANDARLANE, MARIKUPPAM POST KGF-563119 on 28/03/2025 (Date of Inspection) and on the basis of water test Report (Attached bearing no NALRC/2025/05/W/556 Dated 03/04/2025 of National Analytical Laboratory and Research Centre Bangalore (PHED Lab) certified that the R R INTERNATIONAL SCHOOL has safe drinking water facilities for the students and members of staff of the institutions. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T Govt.

This Certificate is valid till 05/04/2026

Signature with Seal

Name

Designation

**M. Sridharan**  
Asst. Executive Engineer  
CMC, Robertsonpet,  
K.G.F. - 563 122

To

RR International School,  
BM Road Opp Pandarlane,  
Marikuppam Post KGF-563119



**TEST REPORT**

Name & Address of the Customer

: R.R. International School  
B M Road Opp  
Pandaram Lane,  
Marikuppam,  
K.G.F. -563119

Date of Sample Collection

: 29/03/2025

Particulars of sample

: Drinking Water

Sample Qty: 2 Liters+500ml, Sampling Type: Grab

Sampling Point: Not Specified

Date of sample Receipt

: 29/03/2025

Sample ID/Code

: NALRC/2025/04/W/556

Date of Analysis Started

: 29/03/2025

Date of completion

: 03/04/2025

Report No

: NALRC/2025/05/W/556

Report Date

: 03/04/2025

Page No

: 1/2

Description:-

: Colorless, Odorless, transparent liquid

Sl No	Parameters	Results	Requirement Acceptable Limits	Permissible limit in the absence of alternate source	Test Method
			(As per IS 10500:2012)		
01	Colour, Hazen Units	<1.0	5	15	IS 3025 (P-04):2021
02	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (P-05):2018
03	pH Value	6.6	6.5-8.5	No relaxation	IS 3025 (P-11):2022
04	Turbidity, NTU	0.2	1	5	IS 3025 (P-10):2022
05	Conductivity, $\mu S/cm$	84.0	---	---	IS 3025 (P-14):1984 RA 2019
06	Total Dissolved Solids, mg/L	50.0	500	2000	IS 3025 (P-16):2023
07	Total Hardness as $CaCO_3$ , mg/L	16.0	200	600	IS 3025 (P-21):2009 RA 2019
08	Calcium as Ca, mg/L	3.0	75	200	IS 3025 (P-40):1991 RA 2019
09	Magnesium as Mg, mg/L	2.0	30	100	IS 3025 (P-46):1994 RA 2019
10	Chloride as Cl, mg/L	8.0	250	1000	IS 3025 (P-32):1988 RA 2019
11	Total Alkalinity as $CaCO_3$ , mg/L	21.0	200	600	IS 3025 (P-23):1986 RA 2019
12	Residual Free Chlorine as $Cl_2$ , mg/L	<0.2	Min 0.2	Min 1.0	IS 3025 (P-26):2021
13	Boron as B, mg/L	<0.1	0.5	1.0	APHA 23rd Edition 4500B B
14	Fluoride as F, mg/L	0.30	1.0	1.5	APHA 23rd Edition 4500F D
15	Nitrate as $NO_3$ , mg/L	2.4	45	No relaxation	APHA 23rd Edition 4500NO3 B
16	Iron as Fe, mg/L	<0.05	1.0	No relaxation	APHA 23rd Edition 3500-Fe B
17	Sulphate as $SO_4$ , mg/L	<1.0	200	400	APHA 23rd Edition 4500SO <sub>4</sub> -E
18	Aluminum as Al, mg/L	<0.005	0.03	0.2	IS 3025 (P-2):2019
19	Manganese as Mn, mg/L	<0.005	0.1	0.3	IS 3025 (P-2):2019
20	Selenium as Se, mg/L	<0.005	0.01	No relaxation	IS 3025 (P-2):2019
21	Copper as Cu, mg/L	<0.005	0.05	1.5	IS 3025 (P-2):2019
22	Zinc as Zn, mg/L	<0.005	5	15	IS 3025 (P-2):2019
23	Cadmium as Cd, mg/L	<0.003	0.003	No relaxation	IS 3025 (P-2):2019
24	Total chromium, mg/L	<0.005	0.05	No relaxation	IS 3025 (P-2):2019
25	Lead as Pb, mg/L	<0.005	0.01	No relaxation	IS 3025 (P-2):2019
26	Barium as Ba, mg/L	<0.005	0.70	No relaxation	IS 3025 (P-2):2019
27	Nickel as Ni, mg/L	<0.005	0.02	No relaxation	IS 3025 (P-2):2019
28	Arsenic as As, mg/L	<0.005	0.01	0.05	IS 3025 (P-2):2019

**TEST REPORT**

Name & Address of the Customer

: R R International School  
B M Road Opp  
Pandaram Lane,  
Marikuppam,  
K.G.F. -563119

Date of Sample Collection  
Particulars of sample

: 29/03/2025  
: Drinking Water  
Sample Qty: 2 Liters+500ml, Sampling Type: Grab  
Sampling Point: Not Specified

Date of sample Receipt  
Sample ID/Code  
Date of Analysis Started  
Date of completion  
Report No  
Report Date  
Page No  
Description

: 29/03/2025  
: NALRC/2025/04/W/556  
: 29/03/2025  
: 03/04/2025  
: NALRC/2025/05/W/556  
: 03/04/2025  
: 2/2  
: Colorless, Odorless, transparent liquid

Min: Minimum

Sl No	Parameters	Results	Requirement Acceptable Limits	Permissible limit in the absence at alternate source	Test Method
			(As per IS 10500:2012 )		
01	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (P-08)1984 RA 2017
02	Phenolic compounds as C <sub>6</sub> H <sub>5</sub> OH, mg/L	<0.001	0.001	0.002	IS 3025 (P-43)1992 RA 2019
Bacteriological Parameters:					
03	Total coliform bacteria CFU/100ml	Not Detected	Shall not be detectable in 100 ml sample		IS 15185 2016 (RA-2021)
04	E. coli, CFU/100ml	Not Detected	Shall not be detectable in 100 ml sample		IS 15185 2016 (RA-2021)

Note: The Test Residual free Chlorine is applicable only when water is chlorinated.

Remarks: -The given sample meets to Acceptable limits as per IS 10500:2012 for above Physico - chemical testing & bacteriological tests.

\*\*\*\*\* End of the Report \*\*\*\*\*